



PROJECT: **JACKSON COUNTY
SOLID WASTE MANAGEMENT FACILITY TRANSFER STATION**

DATE: **June 25, 2009**

RFP 9182-01 ADDENDUM No. 3

PAGE: 1 OF 1
Plans and Specifications for the referenced project, as prepared by Moreland Altobelli Associates, Inc., are hereby modified in the following particulars:

A. ADDENDUM NO. 1

1. Modified sketch for detail 11/A5 applies to the Scale Building, not the Transfer building.
2. Modify notes in Detail 11/A5 to indicate 6" faced insulation for roof and 3" faced insulation in walls and to delete note indicating insulation as (R-15 min.).

B. DRAWINGS

1. DRAWING A2

- a. Add note: "SIDEWALL ROOF EDGE AND GUTTERS WILL BE AS STANDARD FOR PRE-ENGINEERED BUILDING MANUFACTURER."
- b. SECTION 1 – Change note for concrete wearing slab to read:
"6" CONCRETE WEARING SLAB W/ WWF ON 10" CONCRETE SUBSLAB, SEE STRUCT."

2. DRAWING A3

- a. Add note: "ALL EXTERIOR GRATING, GRATING SUPPORT STRUCTURE AND CONCRETE SLAB UNDER GRATING SHALL BE BY CONTRACTOR"

3. DRAWING A4

- a. DETAILS 1/A4, 5/A4 and 6/A4 – Modify insulation notes to indicate 6" faced insulation for roof and 3" faced insulation in walls.
- b. Add note: "SIDEWALL ROOF EDGE AND GUTTERS WILL BE AS STANDARD FOR PRE-ENGINEERED BUILDING MANUFACTURER."

4. DRAWING A5 – DETAIL 11/A5 (AS MODIFIED IN ADDENDUM 1)

- a. Modify insulation notes to indicate 6" faced insulation for roof and 3" faced insulation in walls.
- b. Delete note indicating insulation as (R-15 min.)
- c. Detail 2D/A5 – Change concrete note to read: "12" CONCRETE – SEE STRUCTURAL DETAIL L/S2.2 FOR REINFORCING."

5. STRUCTURAL DRAWINGS – GENERAL: Note drawings as plotted are not to scale indicated.

6. DRAWING S1.2

- a. SUB-SLAB ON GRADE SCHEDULE, column "Wearing Slab on Top". Change Type I and II to read: "YES – SEE DRAWING A1" (slab note modified by Addendum No. 1)

7. DRAWING S3.2 – WALL AND FOUNDATION ELEVATION A/S3.2

- a. Add note between column lines 1 and 2 reading:
"WALL AND FOUNDATION SIMILAR ALONG LINE "A"
- b. Add note between column lines 2 and 3 reading:
"WALL AND FOUNDATION TYPICAL ALONG LINE "A" EXCEPT AS INDICATED IN DETAIL L/S2.2"

END OF ADDENDUM No. 3

(TOTAL PAGES IN ADDENDUM NO. 3 : 1 PAGE)

SECTION 00300
 BID (PRICE) PROPOSAL

TO: JACKSON COUNTY BOARD OF COMMISSIONERS

FROM: _____
 Bidder's Name

FOR: TRANSFER STATION, SCALE HOUSE AND APPURTENANCES

Submitted: _____, 2009.

The undersigned Bidder, having examined the contract drawings, and the site of the proposed work and being familiar with all of the conditions surrounding the construction of the proposed project including the availability of equipment and labor, hereby proposes to construct the project in accordance with the contract documents and the Specifications for “**JACKSON COUNTY TRANSFER STATION, SCALE HOUSE AND APPURTENANCES**”.

The Bidder proposes and agrees, if this bid is accepted, to contract with the Jackson County Board of Commissioners in the form of contract agreement specified, to furnish all necessary products, machinery, tools, apparatus, means of transportation, material and labor necessary to complete the construction of the work in full and complete accordance with the reasonably intended requirements of the contract documents for the “**JACKSON COUNTY TRANSFER STATION, SCALE HOUSE AND APPURTENANCES**” and to the full and entire satisfaction of the **Jackson County Board of Commissioners** for the following prices:

	DESCRIPTION	UNITS		UNIT PRICE	AMOUNT
1	MOBILIZATION	1	L.S.	_____	_____
2	SITE DEMOLITION - INITIAL PHASE				
a.	PORTION OF RETAINING WALL	1	L.S.	_____	_____
3	EARTHWORK				
a.	BACKFILL TRANSFER STATION SLAB	1	L.S.	_____	_____
b.	BACKFILL NEW RETAINING WALL	1	L.S.	_____	_____
4	SANITARY SEWER				
a.	48" DIA. MANHOLE	4	EA.	_____	_____
b.	CLEANOUT	2	EA.	_____	_____
c.	8" DIA. D.I.P.	637	L.F.	_____	_____
d.	4" DIA. P.V.C.	75	L.F.	_____	_____
e.	48" DIA. DOGHOUSE M.H.	1	EA.	_____	_____
f.	1,000 GAL. SEPARATOR	1	EA.	_____	_____
g.	S.S. PUMP STATION	1	EA.	_____	_____
h.	4" DIA. FORCE MAIN	360	L.F.	_____	_____
i.	10" TRENCH DRAIN	128	L.F.	_____	_____
5	WATER SERVICE LINE				
a.	8" GATE VALVE	2	EA.	_____	_____
b.	2" GATE VALVE	1	EA.	_____	_____
c.	1" GATE VALVE	1	EA.	_____	_____
d.	FIRE HYDRANT	3	EA.	_____	_____
e.	YARD HYDRANT	2	EA.	_____	_____
f.	8" X 8" TEE	1	EA.	_____	_____
g.	2" X 2" TEE	1	EA.	_____	_____
h.	1" X 1" TEE	1	EA.	_____	_____
j.	8" X 2" REDUCER	1	EA.	_____	_____

k.	8" X 1" REDUCER	1	EA.	_____	_____
l.	8" D.I.P.	340	L.F.	_____	_____
m.	2" D.I.P.	352	L.F.	_____	_____
n.	1" D.I.P.	136	L.F.	_____	_____
p.	BACKFLOW PREVENTER	1	EA.	_____	_____
6	CONSTRUCT BUILDINGS (2 TOTAL)	1	L.S.	_____	_____
7	SITE DEMOLITION - FINAL PHASE				
a.	FINAL SITE DEMOLITION	1	L.S.	_____	_____
8	PAVEMENT				
a.	REINFORCED CONCRETE PAVING	570	S.Y.	_____	_____

BID TOTAL, ITEMS 1 THROUGH 8, INCLUSIVE, THE AMOUNT OF

DOLLARS (\$ _____) (\$ _____)
 Words Figures

The Bidder acknowledges that quantities are not guaranteed and final payment will be based on actual quantities determined as provided in the Contract Documents.

The Bidder agrees hereby to commence work under this Contract, with adequate personnel and equipment, on a date to be specified in a written order of the Owner, and to fully complete all work under this Contract within 240 consecutive calendar days from and including said date.

The Bidder declares that he understands that the quantities shown for unit price items are subject to either increase or decrease, and that should the quantities of any of the items of work be increased, the Bidder proposes to do the additional work at the unit prices stated herein; and should the quantities be decreased, the Bidder also understands that payment will be made on the basis of actual quantities at the unit price bid and will make no claim for anticipated profits for any decrease in quantities; and that actual quantities will be determined upon completion of work, at which time adjustment will be made to the Contract Amount by direct increase or decrease.

In case of discrepancies between the figures shown in the unit prices and the totals, the unit prices shall apply and the totals shall be corrected to agree with the unit prices. In case of discrepancies between written amounts and figures, written amounts shall take precedence over figures and the sum of all Bid extensions (of unit prices) plus lump sum items shall take precedence over BID TOTAL.

The Bidder furthermore agrees that, in the case of a failure on his part to execute the Contract Agreement and Bonds within ten (10) days after receipt of conformed Contract Documents for execution, the Bid Bond accompanying his/her bid and the monies payable thereon shall be paid into the funds of the Owner as liquidated damages for such failure.

Attached hereto is a bid bond for the sum of

Dollars (\$ _____).

According to the provisions of "Invitation to Bid" and provisions thereof.

Bidder: _____

By: _____

(Type Name)

Title: _____

Address: _____

Phone: _____

END OF SECTION